



Atlantic County Utilities Authority

P.O. Box 996 • Pleasantville, NJ, 08232-0996

street address: 6700 Delilah Rd., Egg Harbor Twp., NJ, 08234-5623

609.272.6950 • acua.com

February 24, 2017

Mr. C. Veneziani
Business Administrator
Folsom Public School
1357 Mays Landing Road
Folsom, NJ 08037

Dear Mr. Veneziani:

Please find enclosed the results for the drinking water samples collected on 1/28/17 by your facility, and analyzed for Lead.

Comments:

- A total of 19 samples were received on 2/3/17.
- All 19 samples passed for Lead.
- Your highest concentration in the sample set was 6.05 ug/L.
- The upper limit established in the Lead in Schools regulation is 15.0 ug/L.
- 14 of the 19 samples received tested below the reporting limit of 2.00 ug/L.
- No field blank was received with the sample set.
- This data has been sent to you; copies have been also faxed to Paul Casaccio.
- In addition to the regular lab report, a printed copy of a completed Excel file (Appendix G in the NJDEP Quality Assurance Project Plan (QAPP) Template) has been included. An electronic copy was emailed to Mr. Casaccio.

Keep these copies of the forms for your records.

If there are any questions, please feel free to contact the writer.

Thank you very much.

Sincerely,

A handwritten signature in blue ink, appearing to read 'M. Gille', is written over a light blue horizontal line.

Michael Gille
ACUA Laboratory Director

ACUA Laboratory Multiple Sample Report

Certification No.
NJ 01289

Client: FOLSOM SCHOOL

Sample Date: 2/3/2017

<u>ACUA Sample #</u>	<u>Client #</u>	<u>Analysis</u>	<u>Result</u>	<u>Units</u>	<u>Sample Location</u>
15514	1	Lead	< 2.00	ug/l	Nurse Office sink
15515	2	Lead	< 2.00	ug/l	1st & 2nd Grade Hall Fountain
15516	3	Lead	< 2.00	ug/l	1st & 2nd Grade Hall Fountain
15517	4	Lead	< 2.00	ug/l	Pre-K & K Hall Fountain
15518	5	Lead	< 2.00	ug/l	School Admin. Office, kitchen si
15519	6	Lead	< 2.00	ug/l	Room 103 Water Fountain
15520	7	Lead	< 2.00	ug/l	Room 102 Water Fountain
15521	8	Lead	< 2.00	ug/l	Room 101 Water Fountain
15522	9	Lead	< 2.00	ug/l	Hallway 6 & 7 Fountain #1
15523	10	Lead	< 2.00	ug/l	Hallway 6 & 7 Fountain #2
15524	11	Lead	2.24	ug/l	Room 127 Water Fountain
15525	12	Lead	< 2.00	ug/l	Room 131 Faculty Lounge sink
15526	13	Lead	< 2.00	ug/l	Gym Hall Fountain #1
15527	14	Lead	< 2.00	ug/l	Gym Hall Fountain #2
15528	15	Lead	5.93	ug/l	Kitchen Triple Sink faucet #1
15529	16	Lead	3.13	ug/l	Kitchen Triple Sink faucet #2
15530	17	Lead	6.05	ug/l	Kitchen - Boiler/Hot Pot
15531	18	Lead	4.28	ug/l	Kitchen - Double Sink
15532	19	Lead	< 2.00	ug/l	Kitchen - Ice Machine

Chemist Review _____



2/14/2017

Page 2